


BIDDING DOCUMENTS
FOR THE
HOUSING AUTHORITY OF THE CITY OF SAN BUENAVENTURA

REPLACE ROOFING
DAISY APARTMENTS
10540 DAISY DRIVE
VENTURA CA 93004

Prepared by CONSULTANTS:

AMADOR WHITTLE ARCHITECTS, INC.
28328 Agoura Road, Suite 203
Agoura Hills CA 91301

BID SUBMITTAL
MARCH 1, 2019



William J. Amador, ARCHITECT

BIDDING DOCUMENTS

TABLE OF CONTENTS

DIVISION 00 - PROCUREMENT AND CONTRACTING REQUIREMENTS Number of Pages

00 0101 Project Title Page 01

00 0110 Table of Contents..... 01

DIVISION 01 - GENERAL REQUIREMENTS

01 3300 Submittal Procedures 06

01 7700 Contract Closeout.....02

01 1836 Warranties.....03

DIVISION 02 - EXISTING CONDITIONS

02 4116 Demolition 03

DIVISION 06 - WOOD, PLASTICS, AND COMPOSITES

06 1000 Rough Carpentry 04

DIVISION 07 - THERMAL AND MOISTURE PROTECTION

07 3100 Asphalt Shingle Roofing..... 08

07 6000 Flashing and Sheet Metal..... 05

07 9200 Joint Sealants..... 05

DIVISION 09 - FINISHES

09 9000 Painting and Coating..... 05

END OF TABLE OF CONTENTS

SECTION 01 3300

SUBMITTAL PROCEDURES

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Administrative and procedural requirements for submittals required for the Work, including but not limited to; Shop Drawings, Product Data, Samples, material lists, and quality control items.
- B. Throughout the Contract Documents, the minimum acceptable quality of materials, fabrication, and execution have been defined by the name and catalog number of a manufacturer and by reference of recognized industry standards.
- C. To ensure that specified products are furnished and installed in accordance with the design intent, procedures have been established for submittal of design data and for its review by ARCHITECT, OWNER and others.

1.02 RELATED REQUIREMENTS

- A. Section 01 7700: Contract Closeout.
- B. Section 01 7836: Warranties.

PART 2 – PRODUCTS (Not used)

PART 3 - EXECUTION

3.01 PROCEDURES

- A. CONTRACTOR is required to review and approve every submittal and shop drawing prior to transmittal and delivery to ARCHITECT. Should CONTRACTOR determine a submittal contains errors, or does not meet the requirements of the contract, CONTRACTOR shall immediately return the submittals and shop drawings to the producer and expedite the corrections prior to transmitting the submittal to ARCHITECT. Submittals shall not be used by CONTRACTOR to request clarifications or submit questions. CONTRACTOR will affix stamp to each submittal certifying CONTRACTOR has performed, at minimum, the following:
 - 1. Verified the submittal is complete in all respects and follows the requirements of the Contract Documents without variance.

2. Confirmed that no substitutions have been included. If substitutions are included, CONTRACTOR shall eliminate them from the submittal.
 3. Identified any variances from the requirements of the Contract Documents and confirmed that the identified variance meets, but does not exceed the allowable limitations or tolerances as defined in these specifications.
 4. Verified that all submitted materials, dimensions and tolerances are compatible with existing or planned conditions of the Work in order to erect, fabricate, or install the submitted assembly in conformance with the requirements of the Contract Documents.
 5. Coordinated and verified that the dimensions match CONTRACTOR measured field or installation conditions.
 6. Coordinated and verified that the products of separate manufacturers required within any field produced assembly are compatible in all respects for such assembly.
 7. Packaged together all related submittals or shop drawings where such is necessary for a comprehensive ARCHITECT review.
- B. CONTRACTOR shall package each submittal appropriately for transmittal and handling. Transmittal format shall be as required by OWNER. CONTRACTOR shall transmit and deliver ONE ELECTRONIC set of each submittal or re-submittal to ARCHITECT in PDF format.
- C. After ARCHITECT'S review, ARCHITECT will transmit submittals to OWNER, CONTRACTOR, INSPECTOR and others as required. Work shall not commence, unless otherwise approved by OWNER, until approved submittals are transmitted to CONTRACTOR.
- D. CONTRACTOR shall clearly identify any deviations from the Contract Documents on each submittal. Any deviation not so noted even though stamped reviewed is not acceptable.
- E. CONTRACTOR shall coordinate each submittal with fabrication, purchasing, testing, delivery, other submittals, and related activities requiring sequential activity.
- F. Timing of Submittals:
1. The scheduling of submittals shall be sequenced to support the progress of the Work, and shall be:
 - a. Submitted sufficiently in advance of construction, fabrication or installation in order to allow time for transmittal, review,

modification, correction, (and resubmission and re-review when required.)

- b. Phased with adequate time between submittals in order to allow for proper review by the ARCHITECT without negative impact to the Milestones Schedule.
- 7. In case of product substitution, Shop Drawing preparation shall not commence until such time as OWNER accepts or rejects the proposed substitution in accordance with the procedures described in the General Conditions.
- G. If required, resubmit submittals in a timely manner. Resubmit as specified for initial submittal but identify as such. Review times for re-submitted items shall be as per the time frames for initial submittal review.
- H. Shop Drawing preparation shall not commence until such time as CONTRACTOR receives Product Data acceptance.

3.02 SHOP DRAWINGS

- A. Shop Drawings are original drawings prepared by CONTRACTOR, Sub-contractor, supplier, or distributor illustrating some portion of Work by showing fabrication, layout, setting, or erection and shall not be based on reproduced Contract Documents or copied standard information.
- B. Produce Shop Drawings to an accurate scale that is large enough to indicate all pertinent features and methods. Except for templates, patterns, and similar full-size drawings, submit Shop Drawings on sheets at least 8-1/2 by 11 inches but no larger than 24 by 36 inches.
- C. Shop Drawings shall include fabrication and installation drawings, setting diagrams, schedules, patterns, templates, and similar drawings. Include the following information:
 - 1. Dimensions.
 - 2. Identification of products and materials included by sheet and detail number.
 - 3. Compliance with specified standards.
 - 4. Notation of coordination requirements.
 - 5. Notation of dimensions established by field measurement.

3.03 PRODUCT DATA

- A. Collect Product Data into a single submittal for each element of Work or system. Product Data includes printed information, such as manufacturer's installation instructions, catalog cuts, standard color charts, roughing-in diagrams and templates, wiring diagrams, schedules, illustrations, or performance curves.
 - 1. Mark each copy to show or delineate pertinent materials, products, models, applicable choices, or options. Where Product Data includes information on several products that are not required, clearly mark copies to indicate the applicable information. Include the following information:
 - a. Manufacturer's printed recommendations.
 - b. Compliance with trade association standards.
 - c. Compliance with recognized testing agency standards.
 - d. Application of testing agency labels and seals.
 - e. Notation of dimensions verified by field measurement.
 - f. Notation of coordination requirements.
 - g. Notation of dimensions and required clearances.
 - h. Indicate performance characteristics and capacities.

3.04 SAMPLES

- A. Procedure:
 - 1. Submit Samples of sufficient size, quantity, cured and finished and physically identical to the proposed product or material. Samples include partial or full sections or range of manufactured or fabricated components, cuts or containers of materials, color range sets, and swatches denoting color, texture, and/or pattern.
 - a. Mount or display Samples in the manner to facilitate review of qualities indicated. Include the following:
 - 1) Specification section number and reference.

- 2) Generic description of the Sample.
 - 3) Sampling source.
 - 4) Product name or name of manufacturer.
 - 5) Compliance with recognized standards.
 - 6) Availability and delivery time.
2. Submit Samples for review of size, kind, color, pattern, and texture. Submit Samples for a final check of these characteristics with other elements and a comparison of these characteristics between the final submittal and the actual component as delivered and installed.
- a. Where variations in color, pattern, texture, or other characteristic is inherent in the material or product represented, submit at least three (3) multiple units that show the approximate limits of the variations.
 - b. Refer to other Specification sections for requirements for Samples that illustrate materials, fabrication techniques, assembly details, connections, operation, and similar construction characteristics.
 - c. Refer to other sections for Samples to be returned to CONTRACTOR for incorporation into the Work. Such Samples must be undamaged at time of installation. On the transmittal indicate special requests regarding disposition of Sample submittals.
 - d. Samples not incorporated into the Work, or otherwise not designated as Owner property, remain the property of CONTRACTOR and shall be removed from the Project site prior to Substantial Completion.
3. Color and Pattern: Whenever a choice of color or pattern is available in a specified product, submit accurate color chips and pattern charts to OWNER for review and selection.
4. Number Required: Submit three, minimum, of each. Two will be returned to CONTRACTOR.
- C. Maintain sets of Samples, as returned, at the Project site, for quality comparisons throughout the course of the Work. Sample sets may be used to obtain final acceptance of the Work associated with each set.

3.05 QUALITY CONTROL SUBMITTALS

- A. Submit quality control submittals, including design data, certifications, manufacturer's field reports, and other quality control submittals as required under other sections of the Contract Documents.
- B. When other sections of the Contract Documents require manufacturer's certification of a product, material, or installation complies with specified requirements, submit a notarized certification from the manufacturer certifying compliance with specified requirements.
- C. Certification shall be signed by an officer of the manufacturer or other individual authorized to sign documents on behalf of the represented company.
- D. Requirements for submittal of inspection and test reports are specified in other sections of the Contract Documents.

END OF SECTION

SECTION 01 7700

CONTRACT CLOSEOUT

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. This Section includes administrative and procedural requirements for Contract Closeout, including but not limited to, the following:
 - 1. Inspection procedures.
 - 2. Project record documents submittal.
 - 3. Operation and maintenance manual submittal.
 - 4. Final cleaning.

1.02 RELATED REQUIREMENTS:

- 1. Section 01 3300 - Submittal Procedures.
- 2. Section 01 7836 - Warranties.

PART 2 – PRODUCTS (Not used)

PART 3 - EXECUTION

3.01 SUBSTANTIAL COMPLETION

- A. Inspection Procedures: On receipt of the Request For Certificate of Substantial Completion, OWNER will authorize commencement of final observation. OWNER, CONTRACTOR and ARCHITECT will inspect the Work.
 - 1. If after inspection of the Work, OWNER does not consider the Work substantially complete, OWNER will notify CONTRACTOR.
 - 2. If after inspection, OWNER considers the Work substantially complete, ARCHITECT shall prepare a comprehensive Punch List of items to be corrected.

- a. ARCHITECT may repeat observations to assure the Work is corrected.
- b. Results of the completed observations will form a partial basis of the requirements for Release of Retention.

3.02 OPERATION AND MAINTENANCE:

- A. Operation and Maintenance Instructions: Prior to Substantial Completion, arrange for each installer of equipment that requires regular operation and maintenance to meet with designated OWNER personnel to provide instruction in proper operation and maintenance. Provide instruction by manufacturer's representatives if installers are not experienced in operation and maintenance procedures. Include a detailed review of the following items:
 1. Maintenance manuals.
 2. Warranties and bonds.
 3. Maintenance agreements and similar continuing commitments.

3.03 FINAL CLEANING

- A. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to the condition expected in a normal, commercial building cleaning and maintenance program. Comply with manufacturer's instructions.
 1. Complete the following cleaning operations before requesting inspection for a certificate of Substantial Completion.
 - a. Remove labels that are not permanent labels.
 - b. Clean exposed exterior and interior hard-surfaced finished to a dust-free condition, free of stains, films, and similar foreign substances. Restore reflective surfaces to their original condition. Leave concrete floors broom clean. Vacuum carpeted surfaces.
 - c. Clean the Project site, including landscape development areas, of rubbish, litter, and other foreign substances. Sweep paved areas broom clean; remove stains, spills, and other foreign deposits. Rake grounds that are neither paved nor planted to a smooth, even-textured surface.

END OF SECTION

SECTION 01 7836

WARRANTIES

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. This Section includes administrative and procedural requirements for warranties, including manufacturers and installer's standard warranties on products and special product warranties.
 - 1. Refer to the General Conditions for terms of the guarantee period for the Work.

1.02 RELATED REQUIREMENTS

- A. Section 01 7700 - Contract Closeout.

PART 2 - PRODUCTS (Not applicable)

PART 3 - EXECUTION

3.01 WARRANTY REQUIREMENTS

- A. Disclaimers and Limitations: Manufacturer's disclaimers and limitations on product warranties shall not relieve CONTACTOR of the warranty of the Work incorporating such materials, products, and equipment. Manufacturer's disclaimers and limitations on warranties do not relieve suppliers, manufacturers, installers, and Subcontractors of the requirement to countersign special warranties with CONTRACTOR.
- B. Standard warranties are preprinted written warranties published by individual manufacturers for particular products and are specifically endorsed by the manufacturer to OWNER.
- C. Special warranties are written warranties required by or incorporated in the Contract Documents, either to extend time limits provided by standard warranties or to provide greater rights for OWNER.
- D. Related Damages and Losses: When correcting failed or defective warranted Work, remove and replace Work that has been damaged as a result of such failure or which must be removed and replaced to provide access for correction of warranted Work.

- E. Reinstatement of Warranty: When Work covered by a warranty has failed and been corrected by replacement or rebuilding, reinstate the warranty by written endorsement with the reinstated warranty equal to the original warranty.
- F. Replacement Cost: Upon determination the Work covered by a warranty has failed and/or is defective, replace or rebuild the Work to an acceptable condition complying with requirements of the Contract Documents. CONTRACTOR is responsible for the cost of replacing or rebuilding defective Work regardless of whether OWNER has benefited from use of the Work through a portion of its anticipated useful service life.
- G. OWNER Recourse: Expressed warranties made to OWNER are in addition to implied warranties and shall not limit the duties, obligations, rights, and remedies otherwise available under the law. Expressed warranty periods shall not be interpreted as limitations on the time in which OWNER can enforce such other duties, obligations, rights, or remedies.
- H. Rejection of Warranties: OWNER reserves the right to reject warranties and to limit selection to products with warranties not in conflict with requirements of the Contract Documents.
- I. Where the Contract Documents require a special warranty, or similar commitment on the Work or part of the Work, OWNER reserves the right to refuse to accept the Work until CONTRACTOR presents evidence the entities required to countersign such commitments have done so.

3.02 SUBMITTALS

- A. Submit written preliminary warranties prior to Substantial Completion and final warranties prior to Contract Completion. If the certificate of Substantial Completion designates a commencement date for warranties other than the date of Substantial Completion for the Work, submit written warranties as set forth in the certificate of Substantial Completion.
 - 1. When a designated portion of the Work is partially used and/or occupied by OWNER, submit properly executed warranties to ARCHITECT within fifteen days of the Partial Use or Occupancy of the designated portion of the Work.
- B. When the Contract Documents require CONTRACTOR, or CONTRACTOR and a Subcontractor, installer, supplier or manufacturer to execute a special warranty, prepare a written document containing appropriate terms and identification, ready for execution by the required parties. Submit a draft to OWNER, through the ARCHITECT, for approval prior to final execution.
- C. Form of Submittal: Prior to Contract Completion, compile two copies of each required final warranty properly executed by CONTRACTOR, or by

CONTRACTOR and Subcontractor, installer, supplier, or manufacturer. Organize the warranty documents into an orderly sequence based on the Specifications.

- D. Bind warranties and bonds in heavy-duty, commercial-quality, durable three ring, vinyl-covered loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8½ by 11 paper.
1. Provide heavy paper dividers with celluloid covered tabs for each separate warranty. Mark the tab to identify the item or installation. Provide a typed description of the product or installation, including the name of the product, and the name, address, and telephone number of the installer.
 2. Identify each binder on the front and spine with the typed or printed title “WARRANTIES,” Project title and/or name, and name of CONTRACTOR.
 3. When warranted Work requires operation and maintenance manuals, provide additional copies of each required warranty, as necessary, for inclusion in each required manual.

END OF SECTION

SECTION 02 4116

DEMOLITION

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Furnishing labor, materials and equipment necessary for demolition, dismantling, cutting and alterations as indicated, specified, or required for completion of the Work. Includes items such as the following:
 - 1. Protection of existing improvements to remain.
 - 2. Cleaning existing improvements to remain.
 - 3. Removing debris, waste materials, and equipment.
 - 5. Removal of items for performance of the Work.
 - 6. Salvageable items to be retained by the Owner.
- B. Related Requirements:
 - 1. Division 01 - General Requirements.

1.02 QUALITY ASSURANCE

- A. Perform the Work of this section by workers skilled in the demolition of buildings and structures. Perform the Work of this section under direct superintendence at all times.
- B. Prior to commencement of Work, schedule a walkthrough with the OWNER, to confirm Owner property items have been removed from scheduled Work areas. Identify and mark remaining property items and schedule their removal.
- C. Coordinate demolition for the correct sequence, limits, and methods. Schedule demolition Work to create least possible inconvenience to the public and facility operations.
- D. Related Standard: ANSI/ASSE A10.6.

1.04 PROJECT CONDITIONS

- A. Drawings may not indicate in detail all demolition Work to be performed. Examine existing conditions to determine the full extent of required demolition.
- B. Repair damage to existing improvements or damage due to excessive demolition.
- C. Provide all measures to avoid excessive damage from inadequate or improper means and methods, improper shoring, bracing or support.

- D. If conditions are encountered that varies from those indicated, promptly notify the Architect for clarification before proceeding.

PART 2 - PRODUCTS

2.01 HANDLING OF MATERIALS

- A. Items scheduled for salvage by the Owner shall be delivered to a location designated by the OWNER. Items shall be cleaned, packaged and labeled for storage.
- B. Items scheduled for reuse shall be stored on the Project site and protected from damage, theft and other deleterious conditions.

PART 3 - EXECUTION

3.01 GENERAL

- A. Protection:
 - 1. Do not commence demolition until safety partitions, barricades, warning signs and other forms of protection are installed.
 - 2. Provide safeguards, including warning signs, lights and barricades, for protection of workers, occupants, and the public.
- B. If safety of existing construction appears to be endangered, take immediate measures to correct such conditions; cease operations and immediately notify the OWNER.

3.02 DEMOLITION

- A. Do not throw or drop materials. Furnish ramps or chutes as required by the Work.
- B. Remove existing construction only to extent necessary for proper installation of Work and interfacing with existing construction. Cut back finished surfaces to straight, plumb or level lines as required for a smooth transition.
- C. Where openings are cut oversize or in improper locations, replace or repair to required condition.

3.03 REMOVAL OF OTHER MATERIALS

- A. Woodwork: Cut or remove to a joint or panel line.
- B. Roofing: Remove as required, including accessory components such as insulation and flashings. At penetrations through existing roofing, trim cut edges back to sound roofing with openings restricted to the minimum size necessary to receive Work.
- C. Sheet Metal: Remove back to joint, lap, or connection. Secure loose and unfastened ends or edges and provide a watertight condition. Re-seal as required.
- D. Remove existing improvements not specifically indicated or required but necessary to perform Work. Cut to clean lines, allowing for installation of Work.

3.06 PATCHING

- A. Patch or repair materials to remain when damaged by the performance of the Work of this section. Finish material and appearance of patch and/or repair Work shall match existing.

3.07 CLEANING

- A. Clean existing materials to remain with appropriate tools and equipment.
- B. Protect existing improvements during cleaning operations.
- C. Debris shall be dampened by fog water spray prior to transporting by truck.
- D. Debris pick-up area shall be kept broom-clean and shall be washed daily with clean water.
- E. Remove waste and debris, other than items to be salvaged. Turn over salvaged items to Owner, or store and protect for reuse where required. Continuously clean up and remove items as demolition Work progresses.
- F. Remove rubbish, debris, and waste materials and legally dispose of off the Project site.

END OF SECTION

SECTION 06 1000
ROUGH CARPENTRY

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Rough carpentry Work.
- B. Related Requirements:
 - 1. Division 01 - General Requirements.

1.02 SYSTEM DESCRIPTION

- A. Regulatory Requirements:
 - 1. Work of this Section shall comply with CBC Chapter 23.

1.03 QUALITY ASSURANCE

- A. Comply with the following as a minimum requirement:
 - 1. Douglas fir, larch or hemlock structural and framing lumber shall be graded in accordance with the Standard Grading Rules of the West Coast Lumber Inspection Bureau (WCLIB) or the Western Lumber Grading Rules of the Western Wood Products Association (WWPA).
 - 2. Plywood shall conform to requirements of Product Standard PS 1, and shall be grade marked by a recognized grading agency (APA and PTL).
- B. Lumber shall bear official grade mark of the association under whose rules it was graded or official grade mark of another recognized grading agency.
- C. Structural and framing members 2-inch thick (nominal) and larger shall be air-dried to moisture content not to exceed 19 percent before installation.
- D. Each piece of preservative treated lumber shall be identified by the Quality Mark of an approved inspection agency in accordance with CBC Chapter 23.
- E. Lumber showing visible signs of mold growth:

1. Lumber showing visible signs of mold growth shall be removed from the project site or cleaned as outlined below.
2. The contractor is responsible for all costs associated with cleaning, post-cleaning testing, and reporting for lumber with mold.
 - a. Lumber that shows visible signs of mold growth prior to, or after installation, shall be cleaned pursuant to the current edition of USEPA’s guidance publication “Mold Remediation in Schools and Commercial Buildings (EPA 402-K-01-001).
 - b. A minimum of 10 percent of the total locations cleaned must be sampled (tape lift method) post cleaning to ensure cleaning effort was successful. Cleaning will be considered acceptable when tape lift sample results evaluated by direct microscopic examination determine that the general abundance of mold is non-detect or rare (normal trapping to 1+).
 - c. Cleaned lumber must meet moisture content requirements as required elsewhere in this specification prior to installation or application of finishes.

1.04 STORAGE, HANDLING AND PROTECTION

- A. The materials supplied as part of the Work of this section shall be protected from exposure to inclement weather before being covered by other Work.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Lumber: Structural and framing lumber shall be of following species and grades:

	<u>INSTALLATION</u>	<u>SPECIES</u>	<u>GRADE</u>
1.	roof sheathing and ceiling furring	Douglas fir and larch	Construction Board, WCLIB; WWPA
2.	Framing lumber (2 to 4-inch thick, 5-inch and wider).	Douglas fir and Larch	No. 1 or better Structural Joists and Planks, WCLIB; WWPA.

- B. Plywood: Plywood furnished for structural purposes, when exposed outdoors, shall be exterior type plywood. Other plywood furnished for structural purposes shall be exterior type, or Exposure 1.
- C. Adhesive: Elastomeric adhesive – follow manufacturer’s installation instructions. Product must be approved by OWNER Office of Environmental Health and Safety and conform to ASTM D 3498 or APA-AFG-01.

PART 3 - EXECUTION

3.01 FASTENINGS

A. Nails and Spikes:

1. Furnish only common wire nails or spikes whenever indicated, specified or required.
2. Whenever necessary to prevent splitting, holes shall be pre-drilled for nails and spikes.
3. Nails in plywood shall not be overdriven.
4. Machine Applied Nailing: Machine nailing is not permitted for 5/16 inch plywood. Do not permit nail heads to penetrate outer ply. Maintain minimum allowable edge distances when installing nails.

B. Lag Screws:

1. When installing lag screws in a wood member, pre-drill hole as required by the CBC.
2. Lag screws, which bear on wood, shall be fitted with standard steel plate washers under head. Lag screws shall be screwed and not driven into place.

C. Wood Screws: When installing wood screws, pre-drill holes as required by the CBC.

3.02 INSTALLATION

A. Floor Joists, Roof and Ceiling Framing:

1. Wood facias and trims shall be of 2x solid lumber.

B. Roof Sheathing:

1. Plywood roof sheathing shall be Structural I, Grade C-D, Exposure 1, thickness as indicated.

2. Where exposed roof sheathing is indicated, area shall be sheathed solid with dressed and center matched, V-jointed boards of sizes indicated. Boards shall be installed perpendicular to supports.
3. Provide and install metal H-clips of required size, midway between rafters at unsupported edge joints of plywood roof sheathing where rafters are spaced at 24 inches on center. Clips shall be Plyclips, by Timber Fasteners Inc., Panel Clips by Simpson Co., USP Structural Connectors, or equal.

3.03 CLEAN UP

- A. Remove rubbish, debris and waste materials and legally dispose of off the Project site.

3.04 PROTECTION

- A. Protect the Work of this section until Substantial Completion.

END OF SECTION

SECTION 07_3100

ASPHALT SHINGLE ROOFING

PART I GENERAL

1.01 SECTION INCLUDES

- A. Asphalt roofing shingles.
- B. Leak barrier and roof deck protection.
- C. Metal flashing associated with shingle roofing.
- D. Attic ventilation.

1.02 RELATED SECTIONS

- A. Section 06 1000 - Rough Carpentry: Framing, wood decking, and roof sheathing.
- B. Section 07620 - Flashing and Sheet Metal: Sheet metal flashing not associated with shingle roofing; gutters and downspouts.

1.03 REFERENCES

- A. American Society for Testing and Materials (ASTM) - Annual Book of ASTM Standards
 - 1. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
 - 2. ASTM B 209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
 - 3. ASTM B 370 - Standard Specification for Copper Sheet and Strip for Building Construction.
 - 4. ASTM D 3018 - Standard Specification for Class A Asphalt Shingles Surfaced with Mineral Granules.
 - 5. ASTM D 3161 - Standard Test Method for Wind-Resistance of Asphalt Shingles (Fan-Induced Method).
 - 6. ASTM D 3462 - Standard Specification for Asphalt Shingles Made From Glass Felt and Surfaced with Mineral Granules.
 - 7. ASTM D 4586 - Standard Specification for Asphalt Roof Cement, Asbestos-Free.
 - 8. ASTM D 7158 - Standard Test Method for Wind-Resistance of Sealed Asphalt Shingles (Uplift Force/Uplift Resistance Method).
- B. Underwriters Laboratories (UL) - Roofing Systems and Materials Guide (TFWZ.R21)
 - 1. UL 790 - Tests for Fire Resistance of Roof Covering Materials.
 - 2. UL 997 - Wind Resistance of Prepared Roof Covering Materials.
 - 3. UL 2218 - Impact Resistance of Prepared Roof Coverings Materials.
- C. Asphalt Roofing Manufacturers Association (ARMA)
- D. Sheet Metal and Air Conditioning Contractors National Association, Inc. (SMACNA) - Architectural Sheet Metal Manual.
- E. National Roofing Contractors Association (NRCA)
- F. American Society of Civil Engineers (ASCE).

1. ASCE 7 - Minimum Design Loads for Buildings and Other Structures.

G. U.S. Green Building Council (USGBC)

1.04 DEFINITIONS

A. Roofing Terminology: Refer to ASTM D1079 and the glossary of the National Roofing Contractors Association (NRCA) Roofing and Waterproofing Manual for definitions of roofing terms related to this section.

1.05 SUBMITTALS

A. Submit copies of product data sheets, detail drawings and samples for each type of roofing product.

1.06 QUALITY ASSURANCE

A. Manufacturer Qualifications: Provide all primary roofing products, including shingles, underlayment, leak barrier, and ventilation, by a single manufacturer.

B. Installer Qualifications: Installer must be approved for installation of all roofing products to be installed under this section.

1.07 REGULATORY REQUIREMENTS

A. Provide a roofing system achieving an Underwriters Laboratories (UL) Class A fire classification.

B. Install all roofing products in accordance with all federal, state and local building codes.

C. All work shall be performed in a manner consistent with current OSHA guidelines.

1.08 PREINSTALLATION MEETING

A. General: A pre-installation meeting is required.

B. Timing: The meeting shall take place at the start of the roofing installation, no more than 2 weeks into the roofing project.

C. Attendees: Meeting to be called for by manufacturer's certified contractor. Meeting's mandatory attendees shall include the certified contractor and the manufacturer's representative. Non-mandatory attendees shall include the owner's representative, architect or engineer's representative, and the general contractor's representative.

D. Topics: Certified contractor and manufacturer's representative shall review all pertinent requirements for the project, including but not limited to, scheduling, weather considerations, project duration, and requirements for the specified warranty.

1.09 DELIVERY, STORAGE, AND HANDLING

A. Store all products in manufacturer's unopened, labeled packaging until they are ready for installation.

B. Store products in a covered, ventilated area, at temperature not more than 110 degrees F (43 degrees C); do not store near steam pipes, radiators, or in direct sunlight.

C. Store bundles on a flat surface. Maximum stacking height shall not exceed manufacturer's recommendations. Store all rolls on end.

D. Store and dispose of solvent-based materials in accordance with all federal, state and local regulations.

1.10 WEATHER CONDITIONS

A. Proceed with work only when existing and forecasted weather conditions will permit work to be performed in accordance with manufacturer's recommendations

1.11 WARRANTY

A. Provide to the owner a **GAF® WeatherStopper® Golden Pledge® Ltd Warranty** covering:

1. Roofs installed by a Certified GAF Master Elite™ Contractor only.
2. Manufacturing defects: 100% coverage for materials and labor for:
 - a 40 years with the first 20 years non-prorated.
3. Workmanship errors: 100% coverage for workmanship errors for:
 - a 20 years.
4. All StainGuard Plus™ with Time-Release-labeled shingles carry a 25-year limited warranty against algae discoloration and a Smart Choice® Protection Period of 10 years. All StainGuard®-labeled Shingles and Ridge Cap Shingles carry a 10-year limited warranty against algae discoloration and a Smart Choice® Protection period of 1 year.
5. Roof system NOT installed over an existing roof, all existing roof materials must be removed to the deck.
6. Full roof installations (Roofs installed on portions of buildings do not qualify) using the following GAF products.
 - a You must use GAF Roof Deck Protection.
 - b You must use eligible GAF Leak Barrier in valleys and around dormers, sidewalls, firewalls, chimneys, plumbing vents, and skylights. In the North, leak barriers must be used at all eaves at least 24" inside warm wall.
 - c You must use GAF pre-cut starter strip products (only those with factory applied adhesive) at the eaves. Note: To obtain bonus wind coverage, you must use GAF pre cut starter strip products (with factory applied adhesive) at the eaves and rakes and you must install each shingle using 6 nails. For Miami Dade County Florida, no adhesive on rakes. You must cement the starter strip in and nail along the rake.
 - d You must use eligible COBRA® ventilation with adequate intake ventilation. Master Flow® exhaust ventilation products can be substituted only if COBRA® ridge ventilation cannot be installed due to a structure's architecture. In any event, adequate ventilation should meet the following requirements:

Minimum net free ventilation area of 1 sq ft per 150 sq ft of ceiling area is required. When intake vents are located at the eaves and exhaust vents are located near the roof's peak (in a properly balanced system) for maximum air flow, ventilation may be reduced to 1 sq ft per 300 sq ft. If these standards are not met, GAF cannot be responsible for damage caused by inadequate ventilation.
 - e You must use eligible GAF roofing shingles.
 - f You must use GAF Ridge Cap Shingles or shingles that correspond to the shingle product you are installing.
 - g New metal flashings must be installed. Metal drip edge must be used at eaves and is recommended at rake edges.
7. In addition to the requirements listed above, you installer must register and pay for this warranty. On projects that total more than 250 squares, the permanent Golden Pledge® Ltd Warranty will be issued only if the project passes GAF's final inspection.

GAF reserves the right to withhold the warranty if the roof has not been installed according to GAF's written application instructions. GAF also strongly recommends that your Master Elite® Contractor schedule a start-up and at least one interim inspection on projects of 250 squares or more by contacting GAF at least three weeks prior to the start of roof work.

PART II PRODUCTS

2.01 MANUFACTURERS

- A. Acceptable Manufacturer: GAF, 1 Campus Drive, Parsippany NJ 07054. Tel: 1-973-628-3000.
- B. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.02 SHINGLES

- A. Self sealing, granule surfaced, asphalt shingle with a strong fiberglass reinforced Micro Weave® core and features highly reflective roofing granules that bounce back the sun's rays and more effectively release absorbed heat. Architectural laminate styling provides a wood shake appearance with a 5 5/8 inch exposure. Features GAF®'s patented High Definition® color blends and enhanced shadow effect. UL 790 Class A rated with UL 997 Wind Resistance Label; ASTM D 7158, Class H; ASTM D 3161 Class F; ASTM D 3462; AC438; Texas Dept of Insurance Approved, ICC Report Approval, rated by the Cool Roof Rating Council (CRRC) for use in a Title 24 project, meets Los Angeles Green Building Code. **Timberline HD® Reflector Series™** Lifetime High Definition Shingles, by GAF®.

2.03 HIP AND RIDGE SHINGLES

- A. Distinctive self sealing hip and ridge cap shingle complementing the color of selected roof shingle. Each bundle covers approx. 31 lineal feet (9.45m) with an 8 inch (203mm) exposure. **Ridglass™ 10"** Ridge Cap Shingles by GAF.

2.04 STARTER STRIP

- A. Self sealing starter shingle designed for all roof shingles. Each bundle covers approx. 120 lineal feet (36.58m). **ProStart™ Starter Strip** by GAF.

2.05 LEAK BARRIER

- A. Self-adhering, self sealing, bituminous leak barrier surfaced with fine, skid-resistant granules. Approved by UL, Dade County, ICC, State of Florida and Texas Department of Insurance. Each roll contains approx. 150 sq ft (13.9 sq.m.), 36" X 50' (0.9m x 20.3m) or 200 sq ft (18.6 sq.m.), 36" X 66.7' (0.9m x 20.3m). **WeatherWatch® Leak Barrier**, by GAF.

2.06 SHINGLE UNDERLAYMENT

- A. Superior quality, water repellent, non-asphaltic underlayment. UV stabilized polypropylene construction. Meets or exceeds ASTM D226 and D4869. Each roll contains approximately 10 squares (1003 sq. ft.) of material and is 54" x 223'. **TigerPaw™** Roof Deck Protection, by GAF.

2.07 ROOFING CEMENT

- A. Asphalt Plastic Roofing Cement meeting the requirements of ASTM D 4586, Type I or II.
- B. Roof Cement: ASTM D 4586, **Matrix™ 203 Plastic Roof Cement**.
- C. Roof Cement: ASTM D 4586. **Matrix™ 204 Wet/Dry Roof Cement**.

2.08 ROOF ACCESSORIES

- A. Exterior acrylic rust resistant aerosol roof accessory paint. Each 6 oz can is available in boxes of 6 and in a wide variety of colors to compliment the roof. **Shingle-Match™** Roof Accessory Paint by GAF.

2.09 ATTIC VENTILATION

A. Ridge Vents

1. Flexible ridge ventilator designed to allow the passage of hot air from attics. For use in conjunction with eave/ soffit intake ventilation products. Provides 16.9 inches (1430 mm/m) NFVA (Hand Nail) and 14.1 inches (1193 mm/m) NFVA (Nail Gun) per lineal foot. **Cobra® Exhaust Vent**, by GAF.
2. Rigid plastic ridge ventilator designed to allow the passage of hot air out of attics. For use in conjunction with eave/ soffit intake ventilation products. Provides 18.0 sq inches (11613 sq.mm/m) in NFVA per lineal foot. Each package contains 40 lineal feet (12.19m) of vent. **Cobra® Rigid Vent 3™** ridge vent (includes 3" (76mm) galvanized ring shank nails), by GAF

2.10 NAILS

- A. Standard round wire, zinc-coated steel or aluminum; 10 to 12 gauge, smooth, barbed or deformed shank, with heads 3/8 inch (9mm) to 7/16 inch (11mm) in diameter. Length must be sufficient to penetrate into solid wood at least 3/4 inch (19mm) or through plywood or oriented strand board by at least 1/8 inch (3.18mm).

2.11 METAL FLASHING

- A. .24 gauge hot-dip galvanized steel sheet, complying with ASTM A 653/A 653M, G90/Z275.
- B. 16-oz/sq ft (0.56mm) copper sheet, complying with ASTM B 370.
- C. 0.032-inch (0.8mm) aluminum sheet, complying with ASTM B 209.

PART III EXECUTION

3.01 EXAMINATION

- A. Do not begin installation until the roof deck has been properly prepared.
- B. If roof deck preparation is the responsibility of another installer, notify the architect or building owner of unsatisfactory preparation before proceeding.

3.02 PREPARATION

- A. Remove all existing roofing down to the roof deck.
- B. Verify that the deck is dry, sound, clean and smooth. It shall be free of any depressions, waves, and projections. Cover with sheet metal, all holes over 1 inch (25mm) in diameter, cracks over 1/2 inch (12mm) in width, loose knots and excessively resinous areas.
- C. Replace damaged deck with new materials.
- D. Clean deck surfaces thoroughly prior to installation of eaves protection membrane and underlayment.

3.03 INSTALLATION OF UNDERLAYMENTS

A. General:

1. Install using methods recommended by GAF, in accordance with local building codes. When local codes and application instructions are in conflict, the more stringent requirements shall take precedence.

B. Eaves:

1. Install eaves edge metal flashing tight with fascia boards; lap joints 2 inches (51mm) and seal with plastic cement or high quality urethane sealant; nail at the top of the flange.
2. On all roofs between 2/12 and 4/12 (low slopes) install GAF leak barrier up the slope from eaves edge a full 36 inches (914mm) or to at least 24 inches (610 mm) beyond the interior "warm wall". Lap ends 6 inches (152mm) and bond.

C. Valleys:

1. Install eaves protection membrane at least 36 (914mm) inches wide and centered on the valley. Lap ends 6 inches (152mm) and seal.
2. (OPEN VALLEY'S ONLY): Where valleys are indicated to be "open valleys", install metal flashing over GAF leak barrier before GAF roof deck protection is installed; DO NOT nail through the flashing. Secure the flashing by nailing at 18 inches (457 mm) on center just beyond edge of flashing so that nail heads hold down the edge.

D. Hips and Ridges:

1. Install GAF leak barrier along entire lengths. If ridge vents are to be installed, position the GAF leak barrier so that the ridge slots will not be covered.

E. Roof Deck:

1. Install one layer of GAF roof deck protection over the entire area not protected by GAF leak barrier at the eaves or valley. Install sheets horizontally so water sheds and nail in place.
2. On roofs sloped at 4:12 or greater, lap horizontal edges at least 2 inches (51mm) and at least 2 inches (51mm) over eaves protection membrane.
3. On roofs sloped between 2:12 to less than 4:12, lap horizontal edges at least 19 inches (482 mm) and at least 19 inches (482mm) over eaves protection membrane.
4. Lap ends at least 4 inches (102 mm). Stagger end laps of each layer at least 36 inches (914 mm).
5. Lap GAF roof deck protection over GAF leak barrier in valley at least 6 inches (152mm).

F. Penetrations:

1. Vent pipes: Install a 24 inch (610 mm) square piece of eaves protection membrane lapping over roof deck underlayment; seal tightly to pipe.
2. Vertical walls: Install eaves protection membrane extending at least 6 inches (152mm) up the wall and 12 inches (305mm) on to the roof surface. Lap the membrane over the roof deck underlayment.
3. Rake Edges: Install metal edge flashing over eaves protection membrane and roof deck underlayment; set tight to rake boards; lap joints at least 2 inches (51mm) and seal with plastic cement; secure with nails.

3.04 INSTALLATION OF SHINGLES

A. General:

1. Install in accordance with GAF's instructions and local building codes. When local codes and application instructions are in conflict, the more stringent requirements shall take precedence.

2. Minimize breakage of shingles by avoiding dropping bundles on edge, by separating shingles carefully (not by "breaking" over ridge or bundles), and by taking extra precautions in temperatures below 40 degrees F (4 degrees C).
3. Handle carefully in hot weather to avoid scuffing the surfacing, or damaging the shingle edges.

B. Placement and Nailing:

1. Beginning with the starter strip, trim shingles so that they "nest" within the shingle located beneath it. This procedure will yield a first course that is typically 3" (76mm) to 4" (102mm) rather than a fully exposed shingle.
2. For maximum wind resistance along rakes, install any GAF starter strip containing sealant or cement shingles to underlayment and each other in a 4" (102mm) width of asphalt plastic roof cement.
3. Laterally, offset the new shingles from the existing keyways, to avoid waves or depressions caused by excessive dips in the roofing materials.
4. Using the bottom of the tab on existing shingles, align subsequent courses.
5. *Note: DO NOT install standard sized shingles (5" exposure) over metric (5 5/8" exposure) shingles, as it will overexpose the shingles and reveal the nails. Use standard alignment methods to assure proper shingle placement.
6. Secure with 4, 5, or 6 nails per shingle per GAF's instructions or local codes.
7. Placement of nails varies based on the type of shingle specified. Consult the application instructions for the specified shingle for details.
8. Nails must be driven flush with the shingle surface. Do not overdrive or under drive the nails.
9. Shingle offset varies based on the type of shingle specified. Consult the application instructions for the specified shingle for details.

C. Valleys

1. Install valleys using the "open valley" method:
 - a. Snap diverging chalk lines on the metal flashing, starting at 3 inches (76mm) each side of top of valley, spreading at 1/8 inch per foot (9mm per meter) to the eaves.
 - b. Run shingles to chalk line.
 - c. Trim last shingle in each course to match the chalk line; do not trim shingles to less than 12 inches (305mm) wide.
 - d. Apply a 2 inch (51mm) wide strip of plastic cement under ends of shingles, sealing them to the metal flashing.
2. Install valleys using the "closed cut valley" method:
 - a. Run the first course of shingles from the higher roof slope across the valley at least 12 inches (305mm).
 - b. Run succeeding courses of shingles from the lower roof slope across the valley at least 12 inches (305mm) and nail not closer than 6 inches (152mm) to center of valley.
 - c. Run shingles from the upper roof slope into the valley and trim 2 inches (51mm) from the center line.

D. Penetrations

1. All Penetrations are to be flashed according to GAF, ARMA and NRCA application instructions and construction details.

3.05 INSTALLATION OF ATTIC VENTILATION

A. General

1. Ventilation must meet or exceed current F.H.A., H.U.D. and local code requirements.

B. Ridge / Soffit ventilation

1. Install ridge vent along the entire length of ridges:
2. Cut continuous vent slots through the sheathing, stopping 6 inches (152mm) from each end of the ridge.
3. On roofs without ridge board, make a slot 1 inch (25mm) wide, on either side of the peak (2" (51mm) overall).
4. On roofs with ridge board, make two slots 1-3/4 inches (44.5mm) wide, one on each side of the peak (3 1/2" (89mm) overall).
5. Install ridge vent material along the full length of the ridge, including uncut areas.
6. Butt ends of ridge vent material and join using roofing cement.
7. Install eaves vents in sufficient quantity to equal or exceed the ridge vent area.

3.06 PROTECTION

- A. Protect installed products from foot traffic until completion of the project.
- B. Any roof areas that are not completed by the end of the workday are to be protected from moisture and contaminants.

END OF SECTION

SECTION 07 6000

FLASHING AND SHEET METAL

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Sheet metal flashings in connection with roofing.
 - 2. Coping caps.
 - 3. Gravel stops and metal edging.
 - 4. Gutters and downspouts.
 - 5. Drip flashings.
 - 6. Roof pipe flashings.
- B. Related Requirements:
 - 1. Division 01 - General Requirements.
 - 2. Section 07 3100 - Asphalt Shingles.
 - 3. Section 07 9200 - Joint Sealants.

1.02 SUBMITTALS

- A. Shop Drawings: Submit for fabricated sheet metal indicating shapes, details, methods of joining, anchoring and fastening, thicknesses and gages of metals, concealed reinforcement, expansion joint details, sections, and profiles.
- B. Samples: Submit Samples for materials or assemblies as requested.
- C. Product Data: Submit brochures of manufactured items.

1.03 QUALITY ASSURANCE

- A. Drawings and requirements specified govern. Provide the Work of this section in conformance with the Architectural Sheet Metal Manual published by SMACNA for conditions not indicated or specified and for general fabrication of sheet metal items.
- B. Materials shall conform to following standards:
 - 1. ASTM A167 - Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet and Strip.
 - 2. ASTM A653 - Sheet Steel, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
 - 3. ASTM B370 - Copper Sheet and Strip for Building Construction.

- C. Pre-installation Meetings: Refer to Division 07 roofing sections as appropriate. Attend the pre-installation and inspection meetings for roofing Work.

1.04 DELIVERY, STORAGE AND HANDLING

- A. Do not install bent or otherwise damaged materials.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Galvanized Sheet Steel: ASTM A653, coating designation G60, hot-dip galvanized.
- B. Copper Plate, Sheet and Strip: ASTM B370, cold-rolled, tempered. Copper sheet and strip shall be cold-rolled-temper.
- C. Aluminum Sheet: ASTM B 209, alloy as standard with manufacturer for finish required, with temper as required to suit forming operations and performance required; with smooth, flat surface.
 - 1. As-Milled Finish: Mill.
- D. Fastenings:
 - 1. Galvanized Steel: Nails, rivets, and other fastenings furnished in connection with galvanized sheet steel Work shall be sealed with rust resistive coating. Rivets shall be tinned. Nails and other fastenings shall be zinc-coated.
 - 2. Copper: Nails, rivets, and other fastenings furnished in connection with copper sheet metal Work, shall be manufactured from hard-temper copper or hard brass.
 - 3. Stainless Steel: Nails, rivets and other fastenings furnished in connection with stainless steel Work, shall be 300 series alloy to match alloy of stainless steel being fastened.
- E. Soldering Flux: Raw muriatic acid for galvanized steel; rosin for tin, lead and tinned copper; non-corrosive soldering salts for uncoated copper and acid-type flux formulated for soldering stainless steel.
- F. Solder: ASTM B32, Grade 5A, composed of 95-5 tin-antimony. Name of product manufacturer and grade designation shall be labeled, stamped or cast onto each coil or bar.

2.02 FABRICATION

- A. General:
 - 1. Accurately form sheet metal Work to dimensions and shapes indicated and required. Cope finish molded and brake metal shapes with true, straight, sharp lines and angles and, where intersecting each other, to a precise fit. Unless otherwise specified, all galvanized sheet steel shall be 24 gage. Exposed edges of sheet metal shall have a ½ inch minimum hemmed edge.
 - 2. Soldering of sheet steel or copper shall be performed with well-heated copper soldering iron or soldering torch, joints full flowing, neat and consistent. Fill joint completely with solder. Clean materials at joints before soldering, and tin

coppers before soldering. Exposed soldering on finished surfaces shall be scraped smooth. Lock seam work shall be fabricated flat and true to line and soldered along its entire length. Acid-fluxed Work shall be neutralized after fabrication.

3. Form and install sheet metal Work to provide proper allowances for expansion and contraction, without causing undue stresses in any part of completed Work. Installation shall be water and weathertight.

B. Gutters and Downspouts:

1. Gutters: Fabricate from 24 gage galvanized steel to match existing size and design unless otherwise indicated. Maximum length of gutter shall be 40 feet between end or expansion joints unless the system is specially designed to accommodate the greater expansion, the larger flow and the need for special supports. Drain gutter towards nearest downspout and provide an expansion joint at mid-point between downspout outlets, but not to exceed 40 feet on center. Gutters shall not pond water. Rivet joints and ends with a minimum of 6 rivets per joint or maximum rivet spacing not to exceed 1 ½-inch on center and ½ inch from the edge of the metal, consisting of 3-inch overlap. Sweat solder from inside of gutter and in horizontal position where possible. Neatly fit downspouts to gutter using a slip joint. Provide expansion joints, consisting of 3-inch lap joints at not over feet.
2. Form and install sheet metal Work to provide allowance for expansion and contraction without causing undue stresses in the completed Work.
3. Downspouts: Fabricate downspouts from 3-inch by 4-inch rectangular shapes, 22 gage steel tubing with butt joints and mitered elbows, sized as indicated. . Downspout shall be fabricated with elbows at bottom discharge or connected to drains as indicated.
4. Outlets: Fabricate outlets of 24 gage galvanized sheet steel with a 1/4 inch rolled flanged soldered continuously to gutter. Outside diameter shall be 1/8 inch less than the inside diameter of the downspout and extend into downspout 4 inches. Install a removable wire “bulb type” strainer to outlet opening. Strainer shall be fabricated of 24 gage galvanized steel and ½ inch hardware cloth.

C. Conductor Heads:

1. Fabricate conductor heads and outlets from 24 gage galvanized sheet steel. Cover tops of the conductor heads with 22 gage galvanized ¼ inch wire mesh soldered securely to separately fabricated frame and mechanically fastened to top conductor head with a minimum of two fasteners.

- D. Edge Metal: Provide 24 gage galvanized sheet steel edge metal wherever roof edges are exposed or have gutters; at the eaves and rake of roof. Stops shall be of height indicated and shall be fabricated with two flanges. Horizontal flange shall be not less than 4 inches wide, and vertical flange shall extend down over vertical surfaces of trim or gutter. Edge metal shall lap 4 inches at ends and corners, and shall be fabricated by notching and interlocking vertical face flanges. Contact surfaces of lapped flanges, including raised areas, vertical face and corners, shall be completely covered with

flashing compound. Fabricate lap joints so that they will be in the direction of water flow.

- E. Reglet Type Counterflashing: Where roof comes in contact with vertical surfaces, provide counterflashing. Set top of counter flashing 8 inches above roof deck unless otherwise indicated, and extend down at least 5 inches or to top of cant strip. Counterflashing and reglet shall be 24 gage galvanized sheet steel. Lap counter flashing and reglet 3 inches minimum at splices and miter at angles, or supply special metal corner fittings. Reglet and method of securing flashing shall be so constructed that flashing is firmly locked in place, but may be readily removed for replacement.
- F. Roof Pipe Flashings: Provide prefabricated welded or seamless flashings.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Wood in contact with sheet metal shall be painted with two coats of aluminum paint or one coat of heavy-bodied bituminous paint.

3.02 INSTALLATION

- A. General: Coordinate with installation of underlayment indicated in the Drawings and specified in Section 09 2423.
- B. Gutters and Downspouts:
 - 1. Anchor gutters to structure with 10 gage steel straps, galvanized after fabricating. Secure straps with galvanized fasteners at 3 feet on center. Drill pilot holes and use 12 by 2-inch pan head screws.
 - 2. Install 1/4 inch galvanized wire mesh continuous cover on gutter.
 - 3. Secure downspouts to walls with 1/8 inch by 2-inch galvanized steel straps. Straps shall be located at top, bottom, and at not over 10 feet on center. Block downspouts out 1/2 inch from the finish wall surfaces and 1 inch from the bottom of downspout grade. Secure straps to wall framing with 1/4 inch by 2-inch long galvanized anchors. Expansion type anchors shall be provided when anchoring to concrete and masonry. Provide toggle bolts for attachment to masonry or plaster. At steel columns, provide fasteners as indicated. Plastic anchors are not permitted.
 - 4. Anchor conductor heads to walls with 1/4 inch diameter by 2 1/2-inch long galvanized lag screws or 1/4 inch expansion type anchors.
- C. Reglets: Install reglets at constant height above cant or as indicated. Provide minimum 3-inch lap at end splices of reglets. Seal laps watertight.
- D. Counterflashing:
 - 1. Install at constant horizontal elevation across roof slope and slope at constant height above cant or as indicated.
 - 2. Provide minimum 3-inch lap at all end splices of counterflashing.

- E. Galvanized sheet steel parapet coping and flashing shall be continuous over top of parapet to form a watertight cap, with waterproof seams at approximately 10 feet on center, or as indicated. Anchor coping to outside of wall with a continuous cleat face nailed at 24 inch centers. Coping shall be fastened on inside wall with hex head screws and bonded sealing washers through oversized holes in the back of the coping. Corners and angles shall be lapped and soldered; do not install joint sealant.
- F. Exposed (visible) sheet metal including edge metal, flashings, gutters and downspouts shall be painted per Specification Section 09_9000.

3.03 TESTING

- A. Perform field water testing to demonstrate installation is watertight. Continue testing with a continuous hose stream applied at base of installation for at least 30 minutes. If leaking is observed, discontinue test and repair installation, then test until satisfactory results are obtained.

3.04 PROTECTION

- A. Protect the Work of this section until Substantial Completion.

3.05 CLEANING

- A. Remove rubbish, debris, and waste materials and legally dispose of off the Project site.

END OF SECTION

SECTION 07 9200

JOINT SEALANTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Joint sealants.
 - 2. Preparation for application of sealants.
- B. Related Requirements:
 - 1. Division 01 - General Requirements.
 - 2. Section 06 1000 - Rough Carpentry.
 - 3. Section 07 6000 - Flashing and Sheet Metal.
 - 4. Division 09 - Finishes.

1.02 SUBMITTALS

- A. Shop Drawings: Submit Shop Drawings indicating sealant joint locations, with full-size sealant joint details.
- B. Product Data: Submit manufacturer's literature for each sealant material.
- C. Material Samples: Submit Samples indicating color range available for each sealant material intended for installation in exposed locations.
- D. Certifications: Submit manufacturer's certification materials comply with requirements specified.

1.03 QUALITY ASSURANCE

- A. Qualifications of Installer: The Work of this section shall be installed by a firm which has been in the business of installing similar materials for at least five consecutive years; and can show evidence of satisfactory completion of five projects of similar size and scope. Installer shall have applicators trained and approved by manufacturer for performing this Work.

1.04 DELIVERY, STORAGE AND HANDLING

- A. Store in accordance with manufacturer's recommendations. Provide a uniform ambient temperature between 60 and 80 degrees F.

1.05 WARRANTY

- A. Manufacturer: five year material warranty.
- B. Installer: two year installation/application warranty.

PART 2 - PRODUCTS

2.01 GENERAL

- A. Furnish sealants meeting following in-service requirements:
 - 1. Normal curing schedules are permitted.
 - 2. Non-staining, color fastness (resistance to color change), and durability when subjected to intense actinic (ultraviolet) radiation are required.
- B. Furnish the products of only one manufacturer unless otherwise required, sealant colors as selected to match the adjoining surfaces.

2.02 MATERIALS

- A. Sealants:
 - 1. Sealant 1: Silicone sealant, one-part non-acid-curing silicone sealant complying with ASTM C920, Type S, Grade NS, Class 25.
 - a. Dow Corning Corp., Dow Corning 790, 791, 795.
 - b. General Electric Co., Silpruf.
 - c. Tremco, Inc., Spectrem 1.
 - d. Pecora Corp., 864.
 - e. Equal.
 - 2. Sealant 2: One-part non-sag urethane sealant, complying with ASTM C920, Type S, Grade NS, Class 25.
 - a. Sika Corporation, Sikaflex -221e.
 - b. Equal.
- C. Joint Backing: ASTM D1056; round, closed cell Polyethylene Foam Rod; oversized 30 to 50 percent larger than joint width, reticulated polyolefin foam.
- D. Primer: Non-Staining Type. Provide primer as required and shall be product of manufacturer of installed sealant.
- E. Bond Breaker: Pressure sensitive tape recommended by sealant manufacturer.

- F. Sealants shall have normal curing schedules, shall be nonstaining, color fast and shall resist deterioration due to ultraviolet radiation.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Verify that joint openings are ready to receive Work and field tolerances are within the guidelines recommended by sealant manufacturer.

3.02 SURFACE PREPARATION

- A. Joints and spaces to be sealed shall be completely cleaned of all dirt, dust, mortar, oil, and other foreign materials which might adversely affect sealing Work. Where necessary, degrease with a solvent or commercial degreasing agent. Surfaces shall be thoroughly dry before application of sealants.
- B. If recommended by manufacturer, remove paint and other protective coatings from surfaces to be sealed before priming and installation of sealants.
- C. Preparation of surfaces to receive sealant shall conform to the sealant manufacturer's specifications. Provide air pressure or other methods to achieve required results. Provide masking tape to keep sealants off surfaces that will be exposed in finished Work.
- D. Etch concrete or masonry surfaces to remove excess alkalinity, unless sealant manufacturer's printed instructions indicate that alkalinity does not interfere with sealant bond and performance. Etch with 5 percent solution of muriatic acid; neutralize with dilute ammonia solution, rinse thoroughly with water and allow to dry before sealant installation.
- E. Perform preparation in accordance with ASTM C804 for solvent release sealants, and ASTM C962 for elastomeric sealants.
- F. Protect elements surrounding Work of this section from damage or disfiguration.

3.03 SEALANT APPLICATION SCHEDULE

	<u>Location</u>	<u>Type</u>	<u>Color</u>
A.	Exterior	Sealant 1 or 2	To match adjacent material

3.04 APPLICATION

- A. Provide sealant around all locations indicated or required for structure weatherproofing and/or waterproofing.
- B. Sealants shall be installed by experienced mechanics using specified materials and proper tools. Preparatory Work (cleaning, etc.) and installation of sealant shall be as specified and in accordance with manufacturer's printed instructions and recommendations.

- C. Sealants shall be stored and installed at temperatures as recommended by manufacturer. Sealants shall not be installed when they become too jelled to be discharged in a continuous flow from gun. Modification of sealants by addition of liquids, solvents, or powders is not permitted.
- D. Sealants shall be installed with guns furnished with proper size nozzles. Sufficient pressure shall be furnished to fill all voids and joints solid. In sealing around openings, include entire perimeter of each opening, unless indicated or specified otherwise. Where gun installation is impracticable, suitable hand tools shall be provided.
- E. Sealed joints shall be neatly pointed on flush surfaces with beading tool, and internal corners with a special tool. Excess material shall be cleanly removed. Sealant, where exposed, shall be free of wrinkles and uniformly smooth. Sealing shall be complete before final coats of paint are installed.
- F. Comply with sealant manufacturer's printed instructions except where more stringent requirements are indicated on Drawings or specified.
- G. Partially fill joints with joint backing material, furnishing only compatible materials, until joint depth does not exceed 1/2 inch joint width. Minimum joint width for metal to metal joints shall be 1/4 inch. Joint depth, shall be not less than 1/4 inch and not greater than 1/2 inch.
- H. Install sealant under sufficient pressure to completely fill voids. Finish exposed joints smooth, flush with surfaces or recessed as indicated. Install non-tracking sealant to concrete expansion joints subject to foot or vehicular traffic.
- I. Where joint depth prevents installation of standard bond breaker backing rod, furnish non-adhering tape covering to prevent bonding of sealant to back of joint. Under no circumstances shall sealant depth exceed 1/2 inch maximum, unless specifically indicated on Drawings.
- J. Prime porous surfaces after cleaning. Pack joints deeper than 3/4 inch with joint backing to within 3/4 inch of surface. Completely fill joints and spaces with gun applied compound, forming a neat, smooth bead.

3.05 MISCELLANEOUS WORK

- A. Install sealants to depths as indicated or, if not indicated, as recommended by sealant manufacturer but within following general limitations:
 - 1. For joints in concrete walks, slab and paving subject to traffic, fill joints to a depth equal to 75 percent of joint width, but not more than 3/4 inch deep or less than 3/8 inch deep, depending on joint width.
 - 2. For building joints, fill joints to a depth equal to 50 percent of joint width, but not more than 1/2 inch deep or less than 1/4 inch deep.

3.06 CLEANING

- A. Remove rubbish, debris, and waste materials and legally dispose of off the Project site.

3.07 CURING

- A. Sealants shall cure in accordance with manufacturer's printed recommendations. Do not disturb seal until completely cured.

3.08 PROTECTION

- A. Protect the Work of this section until Substantial Completion.

END OF SECTION

SECTION 09 9000
PAINTING AND COATING

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
1. Exterior painting.

1.02 REGULATORY REQUIREMENTS

- A. Paint materials shall comply with the Food and Drug Administration's (F.D.A.) Lead Law and the current rules and regulations of local, state and federal agencies governing the use of paint materials.

1.03 SUBMITTALS

- A. List of Materials: Before submittal of samples, submit a complete list of proposed paint materials, identifying each material by distributor's name, manufacturer's name, product name and number, including primers, thinners, and coloring agents, together with manufacturers' catalog data fully describing each material as to contents, recommended installation, and preparation methods. Identify surfaces to receive various paint materials.
- B. Material Samples: Submit manufacturer's standard colors samples for each type of paint specified. Once colors have been selected, submit Samples of each color selected for each type of paint accordingly:
1. Samples of Paint and Enamel must be submitted on standard 8 ½" x 11" Leneta Opacity-Display Charts. Each display chart shall have the color in full coverage. The sample shall be prepared from the material to be installed on the Work. Identify the school on which the paint is to be installed, the batch number, the color number, the type of material, and the name of the manufacturer.
 2. Materials and color samples shall be reviewed before starting any painting.

1.04 QUALITY ASSURANCE

- A. Certification of Materials: With every delivery of paint materials, the manufacturer shall provide written certification the materials comply with the requirements of this section.
- B. Coats: The number of coats specified is the minimum number. If full coverage is not obtained with the specified number of coats, install additional coats as required to provide the required finish.

- C. Install coats and undercoats for finishes in strict accordance with the recommendations of the paint manufacturer as reviewed by the Architect.
- D. Paint materials shall comply with the following as a minimum requirement:
 - 1. Materials shall be delivered to Project site in original unbroken containers bearing manufacturer's name, brand number and batch number.

1.05 DELIVERY, STORAGE AND HANDLING

- A. Storage and Mixing of Materials: Store materials and mix only in spaces suitable for such purposes. Maintain spaces clean and provide necessary precautions to prevent fire. Store paint containers so the manufacturer's labels are clearly displayed.

1.06 SITE CONDITIONS

- A. Temperature: Do not install exterior paint in damp, rainy weather or until surface has thoroughly dried from effects of such weather. Do not install paint when temperature is below 50 degrees F, or above 90 degrees F, or dust conditions are unfavorable for installation.

1.07 WARRANTY

- A. Manufacturer shall provide a three year material warranty.
- B. Installer shall provide a three year application warranty.

1.08 MAINTENANCE

- A. Provide at least one gallon of each type, color and sheen of paint coating installed. Label containers with color designation.

PART 2 - PRODUCTS

2.01 PAINT MATERIALS

- A. Furnish the products of only one paint manufacturer unless otherwise specified or required. Primers, intermediate and finish coats of each painting system must all be the products of the same manufacturer, including thinners and coloring agents, except for materials furnished with shop prime coat by other trades.
- B. Factory mix paint materials to correct color, gloss, and consistency for installation to the maximum extent feasible.
- C. Paint materials to be minimum "Architectural Grade".
- D. Gloss degree standards shall be as follows:

HIGH GLOSS	70 and above	EGGSHELL	30 to 47
SEMI-GLOSS	48 to 69	SATIN	15 to 29

2.02 MANUFACTURERS

- A. Acceptable manufacturers, unless otherwise noted:
1. Dunn-Edwards Corporation Paints
 2. Frazee Paints and Wall coverings
 3. Vista Paints
 4. Sherwin Williams
 5. ICI Paints
 6. Equal.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Examine surfaces to receive paint finish. Surfaces which are not properly prepared and cleaned or which are not in condition to receive the finish specified shall be corrected before prime coat is installed.
- B. New woodwork shall be thoroughly cleaned, hand sandpapered, and dusted off. Nail holes, cracks or defects in Work shall be filled. Filling shall be performed after the first coat of paint has been installed.
- C. Metal surfaces to be painted shall be thoroughly cleaned of rust, corrosion, oil, foreign materials, blisters, and loose paint.
- D. Do not install painting materials to wet, damp, dusty, dirty, finger marked, rough, unfinished or defective surfaces.
- F. Mask off areas where necessary.
- G. Existing painted surfaces indicated to be painted, shall be prepared as follows:
1. Wood, plaster and metal surfaces shall be washed with TSP (tri-sodium phosphate) substitute to remove dirt, grease and other foreign materials and rinsed with clean water and then sand papered and dusted off. Surfaces shall have wax completely removed before washing, which includes base, shoe base, and concrete base.
 2. Checked, cracked, blistered, scaled, peeling, and alligatored paint on wood and metal surfaces shall have paint removed down to original finished surface, then hand-sanded and dusted clean.
 3. Surfaces shall then be considered as new work.
 4. Woodwork must be hand sanded smooth after each and every coat, except last coat. Coats shall be free from dust, dirt or other imperfections.

3.02 APPLICATION

- A. Backpainting: Immediately upon delivery to the Project site, finish lumber shall be backpainted on surfaces that will be concealed after installation. Items to be painted shall be backpainted with priming coat specified under "Priming".
- B. Priming: New wood and metal surfaces specified to receive paint finish shall be primed. Surfaces of miscellaneous metal and steel not embedded in concrete, and surfaces of unprimed plain sheet metal Work shall be primed immediately upon delivery to the Project site. Galvanized metal Work and exterior woodwork shall be primed immediately after installation. Priming of surfaces and priming coat shall be as follows:
 - 1. Knots, Pitch and Sap Pockets: Shellac before priming.
 - 2. Exterior Woodwork: Prime with one coat of exterior waterborne emulsion wood primer.
 - 3. Galvanized Metal Work: Clean oil, grease and other foreign materials from surfaces. Install vinyl wash pretreatment coating. Follow manufacturer's instructions for drying time, and then prime with one coat of metal primer.
 - 4. Shop Primed Metal Items: Touch up bare and abraded areas with metal primer before installation of second and third coats.
 - 5. Coats shall be installed evenly and with full coverage. Finished surfaces shall be free of sags, runs and other imperfections.
- C. Allow at least 24 hours between coats of paint.
- D. Rollers shall not be used on wood surfaces.
- E. Each coat of painted woodwork and metal, except last coat, shall be sandpapered smooth when dry.
- F. Paint Roller, brush and spray.
 - 1. First coat on wood overhang and facias shall have material applied by roller and then brushed out in a professional manner to leave surface free of imperfections. Finish coat may be sprayed.
 - 2. Other surfaces shall have all coatings applied with brushes of proper size.

3.03 CLEANING

- A. Remove rubbish, waste, and surplus material and clean woodwork, hardware, floors, and other adjacent Work.
- B. Clean hardware and other unpainted metal surfaces with recommended cleaner. Do not furnish abrasives or edged tools.

3.04 SCHEDULE

A. Exterior:

1. Woodwork: 3 coats.
 - a. First Coat: As specified in this section under Priming.
 - b. Second and Third Coats: Exterior house and trim enamel.
2. Plaster and Stucco: 3 coats. Flat 100 percent acrylic.
 - a. Prime Coat: Alkali resistant primer/sealer.
 - b. Exterior 100 percent acrylic.
3. Metal: 3 coats. Shall be cleaned and pre-treated. Items to be painted include, but are not limited to: steel columns and miscellaneous steel items, gravel stops, metal doors and frames, hoods and flashings.
 - a. First Coat: As specified in this section under Priming.
 - b. Second and Third Coats: Exterior gloss enamel.

3.05 PROTECTION

- A. Protect the Work of this section until Substantial Completion.

3.06 CLEANUP

- A. Remove rubbish, debris, and waste materials and legally dispose of off the Project site.

END OF SECTION